


CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

Jinko Solar Co., Ltd.
No.1 Jinko Road, Shangrao Economic Development Zone,
Shangrao City, Jiangxi Province
334100
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:



Description of product (details see Annex 2):

PV Modules with 6" Poly-crystalline Solar Cells

Tested according to: IEC 60068-2-68:1994 Method Lc2

Valid until: 2018-05-07

Remark: Dust concentration: $5 \pm 0.5 \text{g/m}^3$;
Wind velocity: $9 \pm 2 \text{m/s}$;
Test duration: 4 hours

Registered No.: 44 780 13 406749 - 031

Manufacturer: see Annex 1

Test Report No.: 492010375.001

File No.: SHV01017/13



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Essen, 2013-05-08

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 13 406749 - 031

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: SHV01017/13

2013-05-08

Manufacturer:

Manufacturer:

Jinko Solar Co., Ltd.

No.1 Jinko Road, Shangrao Economic Development Zone,
Shangrao City, Jiangxi Province, 334100, P.R. China

Factory inspection report no.:

862010818.001

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.

A handwritten signature in blue ink, appearing to read "Rogier K.", is positioned above the company name.

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:

PV Modules with 6" Poly-crystalline Solar Cells

JKMSxxxP-72, JKMxxxP-72, JKMxxxPP-72 (xxx=250-305, in steps of 5, 72 cells)

JKMSxxxP-60, JKMxxxP-60, JKMxxxPP-60 (xxx=210-280, in steps of 5, 60 cells)

Maximum system voltage:

1000V

Fuse rating:

15A

Application class:

Class A

Electrical protection class:

Class II

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products