



**Bureau Veritas
Consumer Products Services
Germany GmbH**

Businesspark A96
86842 Türkheim
Deutschland
+ 49 (0) 40 740 41-0
cps-tuerkheim@de.bureauveritas.com

Certificate of compliance

Applicant: KOSTAL Solar Electric GmbH
Hanferstrasse 6
79108 Freiburg
Germany

Product: Disconnection device for PV generators

Model: Elektronischer DC-Freischalter DCS

Use in accordance with regulations:

Disconnection between a solar inverter and a photovoltaic generator

Applied rules and standards :

In dependence on

IEC 60947-3:1999 + Corrigendum:1999 + A1:2001 + Corrigendum 1:2001 + A2:2005

DIN EN 60947-3; VDE 0660-107:2006-03

“Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units”

and

IEC 60364-7-712:2002-05

DIN VDE 0100-712:2006-06

“Electrical Installations of Buildings - Part 7-712: Requirements for Special Installations or Locations - Solar Photovoltaic (PV) Power Supply Systems”

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate of valid safety specifications for the specified use in accordance with regulations.

Report number: 09TH0063-IEC60947
Certificate number: U12-0407
Date of issue: 2012-05-08 **Valid until:** 2015-05-07

Achim Hänchen