

# Certificate

Registration No.: PV 50157013

Page 1

Report No.: 12605932 002

**License Holder:**  
**SANYO Electric Co., Ltd.**  
15-2, Nishiki-Minami-machi  
Kaizuka City, Osaka  
597-0094, JAPAN

**Product:**  
PV Module  
**Type:**  
HIT-xxxHDE4  
HIT-xxxHDE4-2  
xxx = 230, 235, 240, 245, 250

**Manufacturing Plant:**  
**SANYO Hungary Kft.**  
Ipari park, 2510 Dorog  
Hungary

**Basis:**

IEC 61730-1:2004  
IEC 61730-2:2004  
EN 61730-1:2007  
EN 61730-2:2007  
"Photovoltaic (PV) module safety qualification"

**Factory Inspection**  
To document the consistent quality of the product factory inspections are performed periodically.



- Periodic Inspection
- Qualified, IEC 61215
- Safety tested, IEC 61730

**Remarks:**

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21210805.


**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

**The certificate has a validity of 5 years counting from date of issue.**



**Certification body**

  
Dipl.-Ing. W. Herlitschke

Yokohama, 9 June 2009

TÜV Rheinland Japan Ltd. – Yokohama 222-0033, Japan