

Certificate

Registration No.: PV 50163545

Page 2

Report No.: 12606229 002

License Holder:
SANYO Electric Co., Ltd.
15-2, Nishiki-Minami-machi
Kaizuka City, Osaka
597-0094, JAPAN

Product:
PV Module
Type: HIP-214NKHE5

Manufacturing Plant:
SANYO Hungary Kft.
Ipari park, 2510 Dorog
Hungary

Basis:

IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

Factory Inspection
To document the consistent quality of the product factory inspections are performed periodically.



- Periodic inspection
- Qualified, IEC 61215
- Safety tested, IEC 61730

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21210805.


Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 27 August 2013.



Certification body



Dipl.-Ing. W. Herlitschke

Yokohama, 7 September 2009

TÜV Rheinland Japan Ltd. – Yokohama 222-0033, Japan