

Test Verification of Conformity

On the basis of the referenced test report(s), the sample(s) of the below product has been found to comply with the relevant harmonized standard(s) listed on this verification at the time the tests were carried out.

The manufacturer may indicate compliance to said directive(s) by signing a DoC himself and applying the CE-marking to the product identical to the test sample(s) if the product complies with all product relevant CE marking directives. In addition, the manufacturer shall file and keep the documentation according to the rules of the applicable directive(s) and shall consider changes of the standard(s), as they may occur. Additional requirements may be applicable such as additional directives or local laws

Applicant Name & Address	: Schneider Electric Solar Inverters USA, Inc. 250 South Vasco Road, Livermore, CA 94551 USA
Product(s) Tested	: PV Inverter
Ratings and principal characteristics	: DC Input: 180~500 Vdc, Max 12 A AC Output: 230 Vac, 50Hz/60Hz, 18.2 A, 4000VA Max. output power: 4000VA, Max. output current: 18.2 A Class B decive
Model(s)	: CONEXT RL 4000E, CONEXT RL 4000E-S
Brand name	: Schneider
Relevant Standard(s) / Specification(s) / Directive(s)	: EN 301 489-17 V2.2.1/EN 301 489-1 V1.9.2 EN 61000-6-3: 2007+A1: 2011 / EN 61000-6-1: 2007 EN 61000-6-4: 2007+A1: 2011/ EN 61000-6-2: 2005 EN 61000-3-11: 2000 / EN 61000-3-12: 2005/ IEC 61000-3-5: 1994 IEC 61000-4-2: 2008/ EN 61000-4-2: 2009 IEC 61000-4-3: 2010/ EN 61000-4-3:2006+A1:2008+A2:2010 IEC 61000-4-4 :2012/EN 61000-4-4: 2012 IEC 61000-4-5: 2005/ EN 61000-4-5: 2006 IEC 61000-4-6: 2008/ EN 61000-4-6: 2009 IEC 61000-4-8: 2009 / IEC 61000-4-11 :2004/EN 61000-4-11: 2004 IEC 61000-4-16: 2011 / IEC 61000-4-18: 2011 / IEC 61000-4-29: 2000 NOTE: The equipment covered by this document is subject to mandatory compliance with - the European R&TTE Directive, 99/5/EC.
Verification Issuing Office Name & Address	: Intertek Testing Services Taiwan Ltd. No. 11, Lane 275, Ko-Nan 1 Street, Chia-Tung Li, Shiang-Shan District, Hsinchu City, Taiwan
Date of Test(s)	: Mar. 20, 2013 ~ May 17, 2013
Verification/Report Number(s)	: TS13040141-EME(R1) / TS13040141-EME(R1)

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

NOTE 2: This verification supersedes all previous verifications with the noted Verification/Report number(s) : TS13040141-EME dated (May 02, 2013) before this verification notice.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Eric Chu
 ERIC CHU
 LABORATORY MANAGER
 Date: 28 JUN 2013

