



Product Service

CERTIFICATE

No. Z2 09 05 70321 004

Holder of Certificate: Changzhou Trina Solar Energy Co., Ltd.

No. 2 Tian He Road, Electronics Park
New District
213031 Changzhou, Jiangsu
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Poly-crystalline Silicon Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

704060925801-00

Date, 2009-05-08

Page 1 of 2





Product Service

CERTIFICATE
No. Z2 09 05 70321 004

Model(s): TSM-190PC05, TSM-195PC05, TSM-200PC05,
 TSM-205PC05, TSM-210PC05, TSM-215PC05,
 TSM-220PC05, TSM-225PC05, TSM-230PC05,
 TSM-235PC05, TSM-240PC05

Parameters:

Model:	TSM-190PC05, TSM-195PC05,
Rated output power at STC:	190 W, 195 W,
Model:	TSM-200PC05, TSM-205PC05,
Rated output power at STC:	200 W, 205 W,
Model:	TSM-210PC05, TSM-215PC05,
Rated output power at STC:	210 W, 215 W,
Model:	TSM-220PC05, TSM-225PC05,
Rated output power at STC:	220 W, 225 W,
Model:	TSM-230PC05, TSM-235PC05,
Rated output power at STC:	230 W, 235 W,
Model:	TSM-240PC05
Rated output power at STC:	240 W
Application class:	Class A
Max. system voltage:	1000V DC
Test laboratory:	Euro Test Laboratori S.r.l Via dell'Industria, 188 35020 BRUGINE (PD)Italy

Remark:
 The fire test (IEC 61730-2/MST 23) was not performed.

Tested according to: IEC 61215:2005
 IEC 61730-1:2004
 IEC 61730-2:2004
 EN 61215:2005
 EN 61730-1:2007
 EN 61730-2:2007

Production Facility(ies): 70321

Page 2 of 2